

Alabama Department of Environmental Management
adem.alabama.gov

MARCH 22, 2019 1400 Coliseum Blvd. 36110-2400 ■ Post Office Box 301463
Montgomery, Alabama 36130-1463
(334) 271-7700 ■ FAX (334) 271-7950

MR DAN WORTHY
CHAIRMAN
WATER WORKS & SEWER BOARD OF THE CITY OF ASHLAND
POST OFFICE BOX 365
ASHLAND AL 36251

Re: REVISED DRAFT LOCAL LIMITS
WATER WORKS & SEWER BOARD OF THE CITY OF ASHLAND
ASHLAND WWTP
NPDES PERMIT NO. AL0020141


Dear Mr. Worthy:

This letter is to provide notification that ADEM has revised the draft local limits document for the Ashland WWTP. A copy of this draft along with supporting information is attached for your review and comment. ADEM is requesting that your comments be received no later than 30 days from the date of this letter.

Following evaluation of any additional information provided, revised draft local limits will be developed if needed. If your facility has no further comments and does not wish to establish a sampling program, ADEM will proceed with the development of final local limits based on the attached revised draft. After consideration of any comments received during the public notice period, a final determination on the local limits will be made. All permits issued to industrial users must comply with adopted local limits.

Should you have any questions about this process, please contact Scott Jackson by email at scott.jackson@adem.alabama.gov or by phone at (334) 394-4366.

Sincerely,



Scott Ramsey, Chief
Industrial Section
Industrial/Municipal Branch
Water Division

Attachments: Draft Local Limits
Rationale for Local Limits
Local Limits/Pass Through Calculations
List of Significant Industrial Users
Sampling for Local Limit Development

CC: Koch Farms of Ashland LLC
Shanda Torbert
Scott Jackson.



LOCAL LIMITS

PUBLICLY OWNED TREATMENT WORKS: ASHLAND WWTP

LOCATION: ASHLAND, ALABAMA
CLAY COUNTY

PERMIT NUMBER: AL0020141

GENERAL PRETREATMENT PROHIBITIONS

No discharge to the Publicly Owned Treatment Works (POTW) shall exceed or otherwise violate the General Pretreatment Standards described in ADEM Administrative Code 335-6-5. Specifically the POTW shall ensure that discharges to their system comply with the following prohibitions to ensure protection of the treatment and collections systems and to ensure worker safety:

Pollutants which create a fire or explosion hazard including but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit;

Pollutants which will cause corrosive structural damage to the treatment works but in no case discharges with a pH lower than 5.0 S.U. unless the treatment works are specifically designed to accommodate such discharges;

Solid or viscous pollutants in amounts which will cause obstruction to the flow in sewers or other interference with the operation of the treatment works;

Any pollutant, including oxygen demanding pollutants released in a discharge of such volume or strength as to cause interference in the treatment works;

Heat in amounts which will inhibit biological activity in the treatment plant resulting in interference, but in no case in such quantities that the temperature of the effluent at the treatment plant exceeds 104 degrees Fahrenheit unless the treatment plant is designed to accommodate such heat;

Pollutants which will result in the presence of toxic gases, vapors or fumes within the treatment works in a quantity that may cause acute worker health and safety problems;

Any trucked or hauled pollutants except at discharge points designated by the treatment works; and

Petroleum oil, nonbiodegradable cutting oil, or products of mineral origin in such amounts that will cause interference or pass through.

GENERAL PRETREATMENT STANDARDS AND LOCAL LIMITS

POLLUTANTS:

The total average daily loading of the substances from all sources shall not exceed the indicated mass listed below.

<u>Parameter</u>	<u>Allowable Average Daily Pollutant Load at Headworks of POTW</u> (lbs/day)
Arsenic, Trivalent	0.0276
Cadmium, Total Recoverable	0.0256
Chromium, Total Recoverable	13.87
Copper, Total Recoverable	1.120
Cyanide, Free	0.2971
Lead, Total Recoverable	0.1607
Mercury, Total Recoverable	0.0018
Nickel, Total Recoverable	0.5040
Silver, Total Recoverable	0.0307
Zinc, Total Recoverable	4.785

No future loading above the domestic wastewater concentration of Lead or Silver will be allowed. All new or expanding industrial dischargers containing these pollutants shall be limited as indicated below:

<u>Parameter</u>	<u>Allowable Average Concentration</u> (mg/l)
Lead, Total Recoverable	0.05
Silver, Total Recoverable	0.01

HYDRAULIC LOADING:

The hydraulic loading limit on an average basis is the design capacity of the treatment plant which is 1.5 million gallons per day.

ORGANIC LOADING:

The organic loading limit (CBOD₅) is the design capacity of the treatment plant which is 2089 pounds per day.

SOLIDS LOADING

The Total Suspended Solids loading limit (TSS) is the design capacity of the treatment plant which is 2502 pounds per day.

EFFECTIVE DATE:

ISSUANCE DATE:

DRAFT

Alabama Department of Environmental Management

Rationale for Local Limits

Ashland WWTP (AL0020141)
1.07/1.5 MGD Activated sludge facility
Ashland/ Clay County

Reissuance
Prepared Date: 11/26/2018
Prepared By: Ed Hughes
Revised Date: 3/20/2019

Nonconventional Pollutants:

Pass Through:

Allowable pollutant loadings were based on state water quality standards applicable to Horsetrough Creek which has a use designation of Fish & Wildlife. Local limits calculations were performed using a receiving stream 7Q10 of 0.965 cfs, 1Q10 of 0.72 cfs, an annual average flow of 6.97 cfs and a stream hardness of 32.6 mg/l as CaCO₃. The treatment plant removal rates and untreated domestic sewage pollutant concentrations were based on Best Professional Judgment using literature values and EPA recommended levels as the basis unless site specific data was available. Calculations estimate the allowable quantity of heavy metals (measured as Total Recoverable) and Free Cyanide that can be discharged into the POTW to ensure that state water quality standards for aquatic toxicity and human health criteria are met in the receiving stream during critical flow conditions. Because only the portion of heavy metals present in dissolved form is “bioavailable” to aquatic life, the calculations which evaluate aquatic toxicity take into account the relationship between “dissolved” metals and metals measured using the Total Recoverable test procedure. The allowable pollutant loadings based on pass through concerns are located in column 11 of the Local Limits-Pass Through (LL-PT) spreadsheet.

Interference:

The Department evaluated the potential for processes at the POTW to be inhibited as result of the pollutant loading entering the treatment works. Inhibition values were based on Best Professional Judgment using literature values and EPA recommended levels as the basis unless site specific information was provided by the POTW. The allowable pollutant loadings based on inhibition concerns are located in column 13 of the LL-PT spreadsheet.

Sludge Disposal:

The POTW disposes of sludge by land application. The POTW’s NPDES application reports that 20.7 dry tons of biosolids are generated per year based on an average influent flow of 0.339 MGD. That equates to 0.252 tons per day of sludge at the design flow of 1.5 MGD. This value was used in the local limits calculation. For POTWs that use land application as a means of disposal the LL-PT spreadsheet calculates the allowable pollutant loading to ensure that metal concentrations in the sludge comply with EPA 503 regulations for land application of biosolids. The results of these calculations are located in column 14 of the spreadsheet.

Column 15 of the LL-PT spreadsheet indicates the most stringent of the above three criteria. These loadings are considered the POTW’s total headworks capacity for the pollutants of concern.

The LL-PT spreadsheet also lists the current loading of the pollutants of concern from domestic/commercial and industrial sources and determines the remaining capacity currently available. Domestic/commercial loadings are indicated in Columns 16 and current industrial loadings are shown in column 17 (a listing of each significant industrial user and their permit limits and average reported discharge level for pollutants without permit limits is shown on the attached Significant Industrial Users sheet). Column 18 of that spreadsheet shows the remaining capacity after subtracting the current loadings. Negative values indicate that no additional capacity is available for these pollutants. Specifically, these calculations estimate that no additional loading of Lead or Silver above the domestic sewage concentration can be allowed; therefore, new and expanded discharges shall be limited to domestic sewage concentrations.

The limiting factor for each of these pollutants is shown below:

<u>Parameter</u>	<u>Limiting Factor</u>
Lead, Total Recoverable	Water Quality
Silver, Total Recoverable	Water Quality

It should be noted that the available pollutant loadings shown in column 18 have been reduced by 10%, which is the percent of total capacity reserved for future growth.

Conventional Pollutants

Temperature:

The Department is not aware of any specific circumstances related to this POTW which require a temperature limitation more stringent than general standards and prohibitions contained in ADEM Administrative code 335-6-5-.03(2)(e).

pH:

The Department is not aware of any specific circumstances related to this POTW which require a minimum pH limitation more stringent than general standards and prohibitions contained in ADEM Administrative code 335-6-5-.03(2)(b).

Hydraulic loading:

The hydraulic loading limit is the design capacity of the treatment plant as indicated by the POTW, 1.5 MGD.

Organic loading:

The organic loading limit (CBOD₅) is the design capacity of the treatment plant. This loading was calculated using the design flow of the POTW and an influent CBOD₅ concentration of 167 mg/l.

Total Suspended Solids loading

The Total Suspended Solids (TSS) loading was calculated using the design flow of the POTW and an influent TSS concentration of 200 mg/l.

While ADEM develops local limits and reviews compliance, POTWs are responsible for ensuring proper management of Significant Industrial Users and other sources to meet their NPDES limits and to prevent pass through and interference problems and to ensure compliance with the prohibitions contained in ADEM Administrative Code 335-6-5-.03 for protection of the treatment works, collection system and worker safety. The POTWs' responsibilities include establishing any additional limitations via local ordinances, etc. to protect the POTW and comply with their permit.

Revision (3/20/2019):

In this revision the local limit for Chromium was increased after the local limit spreadsheet was modified to remove CFR 503 related limits which were not applicable to this pollutant.

LOCAL LIMIT/ PASS THROUGH CALCULATIONS

POTW NAME: Ashland WWTP
 NPDES PERMIT NUMBER: AL0020141

DATE PREPARED: 11/21/2018
 PREPARED BY: Ed Hughes
 REVISED DATE: 3/20/2019

STREAM DATA AND POTW FLOW DATA					
RECEIVING STREAM CLASSIFICATION	=	F & W	0	RECEIVING STREAM TIDALLY INFLUENCED =	No
POTW DESIGN FLOW	=		1.5 MGD		
FLOW FROM OTHER CONTRIBUTORS	=		MGD		
DOMESTIC FLOW	=		0.8644 MGD		
7Q10	=		0.965 CFS	OR	0.62 MGD
1Q10	=		0.72 CFS	OR	0.47 MGD
7Q2	=		CFS	OR	0.00 MGD
ANNUAL AVG FLOW	=		6.97 CFS	OR	4.50 MGD
STREAM HARDNESS (DEFAULT VALUE 100)	=		32.6 MG/L AS CaCO3		

ALLOWABLE LOADING TO STREAM BASED ON WATER QUALITY AND HH STANDARDS										
PARAMETER	1) CHRONIC	SW CHRONIC	2) MAX W Q	3) ACUTE	SW ACUTE	4) MAX W Q	5) HUMAN	6) MAX W Q	7) WQ / HH	PARAMETER
	TOXICITY	TOXICITY	INSTREAM	TOXICITY	TOXICITY	INSTREAM	HEALTH	INSTREAM	BASED DISC	
	(MG/L)	(MG/L)	(LBS/D)	(MG/L)	(MG/l)	(LBS/D)	(MG/L)	(LBS/D)	LEVEL (LBS/D)	
ANTIMONY, TOTAL RECOVERABLE	----	----	----	----	----	----	0.3733333	18.690	18.690	ANTIMONY, TR
ARSENIC, TRIVALENT	0.1500	----	4.628	0.3400	----	9.721	0.00030	0.015	0.015	ARSENIC, TRI
CADMIUM, TOT RECOVERABLE	0.0001	----	0.008	0.0007	----	0.047	----	----	0.008	CADMIUM, TR
CHROMIUM, TOT RECOVERABLE	0.0296	----	2.496	0.2275	----	17.780	----	----	2.496	CHROMIUM, TR
CHROMIUM, HEXAVALENT	0.0110	----	0.195	0.0160	----	0.263	----	----	0.195	CHROMIUM, HEX
COPPER, TOTAL RECOVERABLE	0.0034	----	0.157	0.0047	----	0.197	----	----	0.157	COPPER, TR
CYANIDE, FREE	0.0052	----	0.092	0.0220	----	0.361	9.3333	165.28	0.092	CYANIDE, FREE
LEAD, TOT RECOVERABLE	0.0007	----	0.063	0.0187	----	1.490	----	----	0.063	LEAD, TR
MERCURY, TOT RECOVERABLE	0.000012	----	0.001	0.0024	----	0.130	0.0000424	0.001	0.00070	MERCURY, TR
MOLYBDENUM	----	----	----	----	----	----	----	----	----	MOLYBDENUM
NICKEL, TOT RECOVERABLE	0.0201	----	0.707	0.1814	----	5.895	0.9929078	17.583	0.707	NICKEL, TR
SELENIUM, TOTAL RECOVERABLE	0.0005	----	0.009	0.0020	----	0.033	2.4305556	43.043	0.009	SELENIUM, TR
SILVER, TOT RECOVERABLE	----	----	----	0.0005	----	0.008	----	----	0.008	SILVER, TR
ZINC, TOT RECOVERABLE	0.0457	----	2.453	0.0453	----	2.254	14.8936170	263.75	2.254	ZINC, TR

DOMESTIC	DATA VALUE	Antimony	Arsenic	Cadmium	Chromium, To	Chromium,VI	Copper	Cyanide	Lead	Mercury	Molybdenum	Nickel	
	LIT VALUE	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
		0.0010	0.0010	0.0030	0.0500	0.0000	0.0600	0.0400	0.0500	0.0000	0.0000	0.0200	
		Selenium	Silver	Zinc									
	DATA VALUE	0.0000	0.0000	0.0000									
	LIT VALUE	0.0000	0.0100	0.1800									

TYPE OF TREATMENT =	2	Act Sludge
TREATMENT INCLUDE NITIFICATION?	No	

SLUDGE DISPOSAL	
DOES THE POTW HAVE SECONDARY CLARIFICATION?	Yes
AVERAGE TONS OF SLUDGE PER DAY (DRY WEIGHT)	0.252
IS SLUDGE LAND APPLIED?	Yes

GROWTH ALLOCATION	
% ALLOCATION RESERVED FOR FUTURE GROWTH =	10

PARAMETER	7) MAX WQ INSTREAM (LBS/D)	8) ALLOCATION FROM BACKGROUND (LBS/D)	9) ALLOWABLE DISC FROM POTW (LBS/D)	10) REMOVAL RATE (%)	11) ALLOWABLE DISCHARGE (LBS/D)	12) INHIBITION TRESHOLD (MG/L)	13) ALLOWABLE DISCHARGE (LBS/D)	14) ALLOWABLE DISCHARGE (LBS/D)	15) ALLOWABLE DISCHARGE LOCAL LIMIT (LBS/D)	16) DOMESTIC INFLUENT LOADING (LBS/D)	17) INDUSTRIAL INFLUENT LOADING (LBS/D)	18) AVAILABLE CAPACITY FOR GROWTH (LBS/D)	LIMITING FACTOR
ANTIMONY, TOT RECOVERABLE	18.6898	0	18.6898	0	18.6898				18.6898	0.0072	0.0000	16.8143	WATER QUALITY
ARSENIC, TRIVALENT	0.0152	0	0.0152	45	0.0276	0.100	1.2510	0.084	0.0276	0.0072	0.0000	0.0183	WATER QUALITY
CADMIUM, TOT RECOVERABLE	0.0085	0	0.0085	67	0.0256	1.000	12.5100	0.063940299	0.0256	0.0216	0.0000	0.0036	WATER QUALITY
CHROMIUM, TOT RECOVERABLE	2.4958	0	2.4958	82	13.8654	5.000	62.5500	---	13.8654	0.3605	0.0000	12.1545	WATER QUALITY
CHROMIUM, HEXVALENT	0.1948	0	0.1948	83	1.1459	1.000	12.5100	----	1.1459	0.0000	0.0000	1.0313	WATER QUALITY
COPPER, TOTAL RECOVERABLE	0.1569	0	0.1569	86	1.1204	1.000	12.5100	2.52	1.1204	0.4325	0.0000	0.6191	WATER QUALITY
CYANIDE, FREE	0.0921	0	0.0921	69	0.2971	0.100	1.2510	----	0.2971	0.2884	0.0000	0.0078	WATER QUALITY
LEAD, TOT RECOVERABLE	0.0627	0	0.0627	61	0.1607	1.000	12.5100	0.694032787	0.1607	0.3605	0.0000	-0.1798	WATER QUALITY
MERCURY, TOT RECOVERABLE	0.0007	0	0.0007	60	0.0018	0.100	1.2510	0.04788	0.0018	0.0000	0.0000	0.0016	WATER QUALITY
MOLYBDENUM		0						0.0378	0.0378	0.0000	0.0000	----	SLUDGE
NICKEL, TOT RECOVERABLE	0.7066	0	0.7066	42	1.2182	1.000	12.5100	0.504	0.5040	0.1442	0.0000	0.3238	SLUDGE
SELENIUM	0.0089	0	0.0089	50	0.0177			0.1008	0.0177	0.0000	0.0000	0.0159	WATER QUALITY
SILVER, TOT RECOVERABLE	0.0077	0	0.0077	75	0.0307	0.250	3.1275	----	0.0307	0.0721	0.0000	-0.0372	WATER QUALITY
ZINC, TOT RECOVERABLE	2.2543	0	2.2543	79	10.7349	1.000	12.5100	4.784810127	4.7848	1.2976	0.0000	3.1385	SLUDGE

Comments

Item 1: Allowable concentration instream based on above noted stream conditions and state standard to protect aquatic life from chronic toxicity.

Item 2: Mass of pollutant allowed instream based on above noted stream conditions and chronic criteria calculated as shown below:

Item 2 = stream 7Q10 x 8.34 x Item 1. If stream segment is tidally influenced, the more stringent of freshwater and saltwater criteria is used.

Item 3: Allowable concentration instream based above noted stream conditions and state standard to protect aquatic life from acute toxicity.

Item 4: Mass of pollutant allowed instream based on above noted stream conditions and acute criteria and calculated as shown below:

Item 4 = stream 1Q10 x 8.34 x Item 3. For LWF streams, Item 4 = stream 7Q2 x 8.34 x Item 3.

If stream segment is tidally influenced, the more stringent of freshwater and saltwater criteria is used.

Item 5: Allowable concentration instream based on above noted stream conditions and state human health standard for a stream with this use classification.

Item 6: Mass of pollutant allowed instream based on above noted stream condition, the human health standard and calculated as shown below:

Item 6 = Annual average stream flow x 8.34 x Item 5 (for carcinogens) and 7Q10 x 8.34 x Item 5 (for non-carcinogens).

Item 7: The most stringent of the requirements calculated in Items 2,4 and 6.

Item 8: Amount allocated to other facilities discharging to this stream segment.

Item 9: Remaining allocation available.

Item 10: Pollutant removal rates based on the treatment process.

Item 11: The calculated allowable discharge into the POTW based on water quality and human health concerns.

Item 12: Concentration of pollutant that could cause inhibition of biological processes utilized at the treatment plant.

Item 13: Allowable discharge into the POTW based on levels to prevent inhibition of biological treatment processes.

Item 14: Allowable discharge into the POTW based on levels to meet EPA 503 standards for land application of sludge, if sludge is land applied.

Item 15: Allowable discharge into the POTW based on the more stringent of Items 11, Item 13 and item 14 requirements. This column contains the Local Limits for this POTW.

Item 16: Domestic influent (lbs/d) based on domestic flow and sampled domestic influent data if available or literature values if not.

Item 17: Industrial influent (lbs/d) based on monthly average permit limits and actual average values for the past 2 to 5 years (depending on availability) for "monitor only" pollutants as shown on SIUs sheet. Values reported as less than detect are not included in average calculation.

Item 18: Available capacity remaining for new sources after subtracting capacity being utilized by industrial sources, domestic sources (including commercial sources and septage disposal) and capacity reserved for future growth.

SIGNIFICANT INDUSTRIAL USERS

PERMITTEE	AVG FLOW (MGD)	DAILY AVG ANTIMONY (MG/L)	DAILY AVG ARSENIC (MG/L)	DAILY AVG CADMIUM (MG/L)	DAILY AVG CHROMIUM (MG/L)	DAILY AVG HEX CHROM (MG/L)	DAILY AVG COPPER (MG/L)	DAILY AVG CYANIDE (MG/L)	DAILY AVG LEAD (MG/L)	DAILY AVG MERCURY (MG/L)	DAILY AVG Molybdenum (mg/l)	DAILY AVG NICKEL (MG/L)	DAILY AVG SELENIUM (MG/L)	DAILY AVG SILVER (MG/L)	DAILY AVG ZINC (MG/L)
Koch Foods (IU341400075)	0.6356	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
Total Industrial flow	0.6356														

Monthly average permit limits are listed in bold print.

Other values are based on a minimum of 24 months of data if available as reported on DMRs (for parameters with testing requirements in permits).

CURRENT PERMITTED INDUSTRIAL LOADING TO POTW (LBS/DAY)

PARAMETER	
ANTIMONY	0.0000
ARSENIC	0.0000
CADMIUM	0.0000
CHROMIUM	0.0000
HEX CHROM	0.0000
COPPER	0.0000
CYANIDE	0.0000
LEAD	0.0000
MERCURY	0.0000
Molybdenum	0.0000
NICKEL	0.0000
SELENIUM	0.0000
SILVER	0.0000
ZINC	0.0000

LOCAL LIMIT/ PASS THROUGH CALCULATIONS

POTW NAME: Ashland WWTP
 NPDES PERMIT NUMBER: AL002014I

DATE PREPARED: 11/21/2018
 PREPARED BY: Ed Hughes
 REVISED DATE: 3/20/2019 5/28/2019

STREAM DATA AND POTW FLOW DATA									
RECEIVING STREAM CLASSIFICATION	=	F & W	0		RECEIVING STREAM TIDALLY INFLUENCED =	No			
POTW DESIGN FLOW	=		1.5	MGD					
FLOW FROM OTHER CONTRIBUTORS	=			MGD					
DOMESTIC FLOW	=		0.8644	MGD					
7Q10	=		0.965	CFS	OR		0.62	MGD	
1Q10	=		0.72	CFS	OR		0.47	MGD	
7Q2	=			CFS	OR		0.00	MGD	
ANNUAL AVG FLOW	=		6.97	CFS	OR		4.50	MGD	
STREAM HARDNESS (DEFAULT VALUE 100)	=		32.6	MG/L AS CaCO3					

ALLOWABLE LOADING TO STREAM BASED ON WATER QUALITY AND HH STANDARDS										
PARAMETER	1) CHRONIC	SW CHRONIC	2) MAX W Q	3) ACUTE	SW ACUTE	4) MAX W Q	5) HUMAN	6) MAX W Q	7) WQ / HH	PARAMETER
	TOXICITY	TOXICITY	INSTREAM	TOXICITY	TOXICITY	INSTREAM	HEALTH	INSTREAM	BASED DISC	
	(MG/L)	(MG/L)	(LBS/D)	(MG/L)	(MG/l)	(LBS/D)	(MG/L)	(LBS/D)	LEVEL (LBS/D)	
ANTIMONY, TOTAL RECOVERABLE	----	----	----	----	----	----	0.3733333	6.611	6.611	ANTIMONY, TR
ARSENIC, TRIVALENT	0.1500	----	4.628	0.3400	----	9.721	0.00030	0.015	0.015	ARSENIC, TRI
CADMIUM, TOT RECOVERABLE	0.0001	----	0.008	0.0007	----	0.047	----	----	0.008	CADMIUM, TR
CHROMIUM, TOT RECOVERABLE	0.0296	----	2.496	0.2275	----	17.780	----	----	2.496	CHROMIUM, TR
CHROMIUM, HEXAVALENT	0.0110	----	0.195	0.0160	----	0.263	----	----	0.195	CHROMIUM, HEX
COPPER, TOTAL RECOVERABLE	0.0034	----	0.157	0.0047	----	0.197	----	----	0.157	COPPER, TR
CYANIDE, FREE	0.0052	----	0.092	0.0220	----	0.361	9.3333	165.28	0.092	CYANIDE, FREE
LEAD, TOT RECOVERABLE	0.0007	----	0.063	0.0187	----	1.490	----	----	0.063	LEAD, TR
MERCURY, TOT RECOVERABLE	0.000012	----	0.001	0.0024	----	0.130	0.0000424	0.001	0.00070	MERCURY, TR
MOLYBDENUM	----	----	----	----	----	----	----	----	----	MOLYBDENUM
NICKEL, TOT RECOVERABLE	0.0201	----	0.707	0.1814	----	5.895	0.9929078	17.583	0.707	NICKEL, TR
SELENIUM, TOTAL RECOVERABLE	0.0005	----	0.009	0.0020	----	0.033	2.4305556	43.043	0.009	SELENIUM, TR
SILVER, TOT RECOVERABLE	----	----	----	0.0005	----	0.008	----	----	0.008	SILVER, TR
ZINC, TOT RECOVERABLE	0.0457	----	2.453	0.0453	----	2.254	14.8936170	263.75	2.254	ZINC, TR

		Antimony	Arsenic	Cadmium	Chromium, To	Chromium,VI	Copper	Cyanide	Lead	Mercury	Molybdenum	Nickel	
DOMESTIC	DATA VALUE	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
	LIT VALUE	0.0010	0.0010	0.0030	0.0500	0.0000	0.0600	0.0400	0.0500	0.0000	0.0000	0.0200	
		Selenium	Silver	Zinc									
	DATA VALUE	0.0000	0.0000	0.0000									
	LIT VALUE	0.0000	0.0100	0.1800									

TYPE OF TREATMENT =	2	Act Sludge	SLUDGE DISPOSAL	
TREATMENT INCLUDE NITIFICATION?	No		DOES THE POTW HAVE SECONDARY CLARIFICATION?	Yes
			AVERAGE TONS OF SLUDGE PER DAY (DRY WEIGHT)	0.252
			IS SLUDGE LAND APPLIED?	Yes
			GROWTH ALLOCATION	
			% ALLOCATION RESERVED FOR FUTURE GROWTH =	10

PARAMETER	7) MAX WQ INSTREAM (LBS/D)	8) ALLOCATION FROM BACKGROUND (LBS/D)	9) ALLOWABLE DISC FROM POTW (LBS/D)	10) REMOVAL RATE (%)	11) ALLOWABLE DISCHARGE (WQ / HH) (LBS/D)	12) INHIBITION TRESHOLD CONC (MG/L)	13) ALLOWABLE DISCHARGE (INHIBITION) (LBS/D)	14) ALLOWABLE DISCHARGE (SLUDGE) (LBS/D)	15) ALLOWABLE DISCHARGE LOCAL LIMIT (LBS/D)	16) DOMESTIC INFLUENT LOADING (LBS / D)	17) INDUSTRIAL INFLUENT LOADING (LBS/D)	18) AVAILABLE CAPACITY FOR GROWTH (LBS/D)	LIMITING FACTOR
ANTIMONY, TOT RECOVERABLE	6.6114	0	6.6114	0	6.6114				6.6114	0.0072	0.0000	5.9438	WATER QUALITY
ARSENIC, TRIVALENT	0.0152	0	0.0152	45	0.0276	0.100	1.2510	0.084	0.0276	0.0072	0.0000	0.0183	WATER QUALITY
CADMIUM, TOT RECOVERABLE	0.0085	0	0.0085	67	0.0256	1.000	12.5100	0.063940299	0.0256	0.0216	0.0000	0.0036	WATER QUALITY
CHROMIUM, TOT RECOVERABLE	2.4958	0	2.4958	82	13.8654	5.000	62.5500	---	13.8654	0.3605	0.0000	12.1545	WATER QUALITY
CHROMIUM, HEXAVALENT	0.1948	0	0.1948	83	1.1459	1.000	12.5100	----	1.1459	0.0000	0.0000	1.0313	WATER QUALITY
COPPER, TOTAL RECOVERABLE	0.1569	0	0.1569	86	1.1204	1.000	12.5100	2.52	1.1204	0.4325	0.0000	0.6191	WATER QUALITY
CYANIDE, FREE	0.0921	0	0.0921	69	0.2971	0.100	1.2510	----	0.2971	0.2884	0.0000	0.0078	WATER QUALITY
LEAD, TOT RECOVERABLE	0.0627	0	0.0627	61	0.1607	1.000	12.5100	0.694032787	0.1607	0.3605	0.0000	-0.1798	WATER QUALITY
MERCURY, TOT RECOVERABLE	0.0007	0	0.0007	60	0.0018	0.100	1.2510	0.04788	0.0018	0.0000	0.0000	0.0016	WATER QUALITY
MOLYBDENUM		0						0.0378	0.0378	0.0000	0.0000	----	SLUDGE
NICKEL, TOT RECOVERABLE	0.7066	0	0.7066	42	1.2182	1.000	12.5100	0.504	0.5040	0.1442	0.0000	0.3238	SLUDGE
SELENIUM	0.0089	0	0.0089	50	0.0177			0.1008	0.0177	0.0000	0.0000	0.0159	WATER QUALITY
SILVER, TOT RECOVERABLE	0.0077	0	0.0077	75	0.0307	0.250	3.1275	----	0.0307	0.0721	0.0000	-0.0372	WATER QUALITY
ZINC, TOT RECOVERABLE	2.2543	0	2.2543	79	10.7349	1.000	12.5100	4.784810127	4.7848	1.2976	0.0000	3.1385	SLUDGE

Comments

Item 1: Allowable concentration instream based on above noted stream conditions and state standard to protect aquatic life from chronic toxicity.

Item 2: Mass of pollutant allowed instream based on above noted stream conditions and chronic criteria calculated as shown below:

Item 2 = stream 7Q10 x 8.34 x Item 1. If stream segment is tidally influenced, the more stringent of freshwater and saltwater criteria is used.

Item 3: Allowable concentration instream based above noted stream conditions and state standard to protect aquatic life from acute toxicity.

Item 4: Mass of pollutant allowed instream based on above noted stream conditions and acute criteria and calculated as shown below:

Item 4 = stream 1Q10 x 8.34 x Item 3. For LWF streams, Item 4 = stream 7Q2 x 8.34 x Item 3.

If stream segment is tidally influenced, the more stringent of freshwater and saltwater criteria is used.

Item 5: Allowable concentration instream based on above noted stream conditions and state human health standard for a stream with this use classification.

Item 6: Mass of pollutant allowed instream based on above noted stream condition, the human health standard and calculated as shown below:

Item 6 = Annual average stream flow x 8.34 x Item 5 (for carcinogens) and 7Q10 x 8.34 x Item 5 (for non-carcinogens).

Item 7: The most stringent of the requirements calculated in Items 2,4 and 6.

Item 8: Amount allocated to other facilities discharging to this stream segment.

Item 9: Remaining allocation available.

Item 10: Pollutant removal rates based on the treatment process.

Item 11: The calculated allowable discharge into the POTW based on water quality and human health concerns.

Item 12: Concentration of pollutant that could cause inhibition of biological processes utilized at the treatment plant.

Item 13: Allowable discharge into the POTW based on levels to prevent inhibition of biological treatment processes.

Item 14: Allowable discharge into the POTW based on levels to meet EPA 503 standards for land application of sludge, if sludge is land applied.

Item 15: Allowable discharge into the POTW based on the more stringent of Items 11, Item 13 and item 14 requirements. This column contains the Local Limits for this POTW.

Item 16: Domestic influent (lbs/d) based on domestic flow and sampled domestic influent data if available or literature values if not.

Item 17: Industrial influent (lbs/d) based on monthly average permit limits and actual average values for the past 2 to 5 years (depending on availability) for "monitor only" pollutants as shown on SIUs sheet. Values reported as less than detect are not included in average calculation.

Item 18: Available capacity remaining for new sources after subtracting capacity being utilized by industrial sources, domestic sources (including commercial sources and septage disposal) and capacity reserved for future growth.