

ADEM
IMPRESSED CURRENT CATHODIC PROTECTION SYSTEM
60-DAY INSPECTION LOG FOR YEAR _____

Questions on how to complete this form should be directed to the Groundwater Branch, UST Compliance Unit at (334) 270-5655

Owner Information

Facility Name:	Owner:
Address:	Address:
City, County, Zip Code:	City, State, Zip Code:
Facility I.D. Number:	Phone Number:

Rectifier Information

Location of Rectifier at Facility:	Rectifier Design Output (Amps):
------------------------------------	---------------------------------

INSPECTION LOG

Inspections are required at least every 60 days.

PLEASE NOTE: If the rectifier is turned on and the volt and/or amp reading recorded below is zero, immediately contact a cathodic protection tester or expert to repair the cathodic protection system.

60 Day Inspection	Date Inspected	Inspector Initials	Rectifier Turned On?	Rectifier DC Output		Rectifier Clock Reading (Hours)
				Volts	Amps	
January						
February						
March						
April						
May						
June						
July						
August						
September						
October						
November						
December						

Date of any Repairs	Description of any Repairs

Comments
